



XCFR2.E220514 Terminal Blocks - Component

Page Bottom

Terminal Blocks - Component

See General Information for Terminal Blocks - Component

CONNECTWELL INDUSTRIES PVT LTD

E220514

D7 / D14, MIDC

PHASE II

DOMBIVLI

MUMBAI, MH 421204 INDIA

Cat. No.	Wire Range	Wire Type	FW	TQ Lb In.	V	A	UG	CA
CDL4U	10-22	Str.,CU	2	7.0	600	30(1) (8)	C	2(105),4
CMT4	10-22	Str.,CU	2	7.0	300	30(8)	C	2(105),4
CMT4S	10-22	Str.,CU	2	7.0	300	30(8)	C	2(105),4
CTS2.5U	12-24	Str.,CU	1	7.0	300	20	C	2(105)
CTS4U	10-22	Str.,CU	2	7.0	600	30(8)	C	2(105),4
CTS6U	8-22	Str.,CU	2	14.0	600	50	C	2(105),4
CTS10U	6-16	Str.,CU	2	14.0	600	65	C	2(105),4
CTS16U	4-20	CU	2	14.0	600	85	C	2(105),4
CTS25U	2-14	Str.,CU	2	35.0	600	115	C	2(105),4
CTS35U	1/0-18	Str.,CU	1	25.0	600	145	C	2(105)
CTS35UN	2-12	Str.,CU	1	25.0	600	130	C	2(105)
CDL4U(O)	10-22	Str.,CU	2	7.0	600	30(8)	C	2(105),4
CGT4U	10-22	Str.,CU	2	7.0	N/A	N/A	C	2(105),4
CGT6N	8-22	CU	2	14.0	N/A	N/A	B,C	2(105),4
CPT(M)	14-22	Str.,CU	2	7.0	300	15	C	2(105),4
CSDL4U	10-22	CU	2	7.0	600	14	C	2(105)
CSFL4U,-4UL	10-22	Str.,CU	2	7.0	600	10	C	2(105),4
CSFL6U	8-22	CU	2	14.0	300	10	C	2(105),4
CDL4U(E)L	10-22	Str.,CU	2	7.0	600	30(8)	C	2(105),4
CDL4U(E)DD	10-22	Str.,CU	2	7.0	600	30(8)	C	2(105),4
CDL4U(I-S)	10-22	Str.,CU	2	7.0	600	30(8)	C	2(105),4
CHD4	12-22	Str.,CU	1	7.0	600	30	C	2(105)
CTS2.5U-N,	22-14	CU	2	7	600	15	B,C,D	2(105),4
CTS2.5U-NCR								
CTS4U-N	10-22	CU	2	7	600	30(8)	B,C,D	2(105),4

CMC1-2	10-22	CU	2	7	600	30(3) (8)	B,C,D	2(105),4
CMC2-2	10-22	CU	2	7	600	30(3) (8)	B,C,D	2(105),4
ODL4U	10-22	CU	2	7	600	30(3) (8)	B,C,D	2(105),4
CMB4	10-22	CU	2	7	300	25	B,C,D	2(105),4
CGT10U	16-8	CU	2	14	N/A	N/A	B,C,D	2(105),4
CGT35U	8-2	CU	1	25	N/A	N/A	B,C,D	2(105)#
CKT4U	10-22	CU	2	7	600	30(8)	B,C,D	2(105),4
CDTTU	16-8	CU	2	14	600	41	B,C,D	2(105),4
DDFL4U	10-22	CU	2	7	600	6.3/	B,C,D	2(105),4
						30(8)		
DDFL4U(E)	10-22	CU	2	7	600	6.3/	B,C,D	2(105),4
						30(8)		
DDFL4U(E)LR	10-22	CU	2	7	600	6.3/	B,C,D	2(105),4
						30(8)		
CDB4	10-8/	CU	2	26/7	600	50/	B,C,D	2(105),4
	10-22					30(8)		
CDB6	10-2/	CU	1/2	35/14	600	100/50	B,C,D	2(105),4
	22-8							
CDB10	8-1/0/	CU	1/2	53/14	600	130/65	B,C,D	2(105),4
	16-6							
CENC4	22-12	CU	2	14	N/A	N/A	B,C,D	2(105),4
CENC16	10-6	CU	2	17.5	N/A	N/A	B,C,D	2(105),4
CENC35	8-2	CU	2	25	N/A	N/A	B,C,D	2(105),4
CPT5	22-14	CU	2	7	300	15(2)	B,C,D	2(105),4
CPT7.5	22-14	CU	2	7	300	15(2)	B,D	2(105)#
DDPT	22-12	CU	2	14	300	20(2)	B,D	2(105),4
CMT4SU	22-14	CU	1	N/A	300	15(2)	B,D	2(105)#
CGT4N	22-10	CU	2	7	N/A	N/A	B,C	2(105),4
CGMT4	22-10	CU	2	7	N/A	N/A	B,C	2(105),4
CSC2.5T	22-14Str.	CU	2	N/A	600	15(4)	B,C	2(105),4
CSCG2.5T	22-14 Str	CU	2	N/A	N/A	N/A	B,C	2(105),4
CSC4T	22-12 Str.	CU	2	N/A	600	20(5)	B,C	2(105),4
CSCG4T	22-12 Str.	CU	2	N/A	N/A	N/A	B,C	2(105),4
CSC6T	22-8 Str.	CU	2	N/A	600	50	B,C	2(105),4
CSC6T1-2	22-8 Str.	CU	2	N/A	600	50	B,C	2(105),4
CSCG6T	22-8Str	CU	2	N/A	N/A	N/A	B,C	2(105),4
CSC2.5T1-2	22-14	CU	2	N/A	600	15(7)	B,C	2(105),4

CSC2.5T2-2	22-14	CU	2	N/A	600	15(7)	B,C	2(105),4
CSCPT2.5T, -T2	22-14	CU	2	N/A	600	15(7)	B,C	2(105),4
CSC4T1-2	22-12	CU	2	N/A	600	20(6)	B,C	2(105),4
CSC4T2-2	22-12	CU	2	N/A	600	20(6)	B,C	2(105),4
CAFL4U	22-10	CU	2	3-7	600	16	B,C	2(105),4#
CAFL4UL	22-10	CU	2	3-7	600	16	B,C	2(105),4#
CAFL4UN	22-10	CU	2	3-7	600	16	B,C	2(105),4#
CTL2.5U	22-12	CU	2	4.5	300	20(6)	B,C	2(105)
CTL2.5UL	22-12	CU	2	4.5	300	20(6)	B,C	2(105),4
CTL2.5UH	22-12	CU	2	4.5	300	20(6)	B,C	2(105),4
CTL2.5UHL	22-12	CU	2	4.5	300	20(6)	B,C	2(105),4
CTS50U	2/0-6	CU	2	60	600	150	B,C	2(105),4
CTS95U	4/0-2	CU	2	160	600	230	B,C	2(105),4
CB4 w/ suffixes /1,/2,/2H,/3,/3H	24-12	CU	2	6	300	20	B,C	2(N/A),4
CB6 w/ suffixes /1,/2H,/3H	22-10	CU	2	6	300	30	B,C	2(N/A),4
CB16 w/ suffixes /2H,/3H	18-6	CU	2	12	300	65	B,C	2(N/A),4
CSTCB4U, CSTSN4U	22-6	CU	1	14	600	65	B,C	2(105)
CSTSB5U, CSTSN5U	22-4	CU	1	25	600	80	B,C	2(105)
DB16	#	CU	2	#	600	80	B, C	2(105)
DB35	##	CU	2	##	600	115	B, C	2(105)
AS2.5	12-22	Sol/Str CU	2	N/A (9)	600	25	B,C	1, 2(85),4
AS2.5/3	12-22	Sol/Str CU	2	N/A (9)	600	25	B,C	1, 2(85),4
AS2.5/4	12-22	Sol/Str CU	2	N/A (9)	600	25	B,C	1, 2(85),4
ADL2.5	12-22	Sol/Str CU	2	N/A (9)	300	25	B,C	1, 2(85),4
ADL2.5(E)D1	12-22	Sol/Str CU	2	N/A (9)	300	25	B,C	1, 2(85),4
ADL2.5(E)D2	12-22	Sol/Str CU	2	N/A (9)	300	25	B,C	1, 2(85),4
ASF4	10-22	Sol/Str CU	2	N/A (9)	600	6.3	B,C	1, 2(85), 4, 5
ASF4(L)	10-22	Sol/Str CU	2	N/A (9)	600	6.3	B,C	1, 2(85), 4, 5
ASDL4	10-22	Sol/Str CU	2	N/A (9)	600	6.3	B,C	1, 2(85), 4, 5
AGT2.5	12-22	Sol/Str CU	2	N/A (9)	N/A (1)	N/A(1)	B,C	2(85), 4
AGT2.5/3	12-22	Sol/Str CU	2	N/A (9)	N/A (1)	N/A(1)	B,C	2(85), 4
AGT2.5/4	12-22	Sol/Str CU	2	N/A (9)	N/A (1)	N/A(1)	B,C	2(85), 4

N/A - Terminal bodies are of ceramic material

(1) Ampere or voltage ratings are not applicable for protective conductor terminal block.

(2) Limited VA ratings of 10A max at 300V general industrial use .

(3) Limited VA ratings of 5A max at 600V general industrial use .

(4) 20A max for factory-wiring only.

(5) 25A max for factory-wiring only.

(6) 25A max for factory-wiring only.

(7) 20A max for factory-wiring only.

(8) Factory-wiring ratings of 35A max, with one No. 10 AWG CU sol.str; 40A max with two No. 12 AWG CU sol/str (solid and stranded wires are not to be intermixed).

(9) Spring force type terminal block.

- Input - (1 hole) No. 8-4 AWG, Tightening Torque 14 Lb-In. Output - (4 holes) No. 14-10 AWG, Tightening Torque 7 Lb-In.
Output - (2 holes) No. 8-4 AWG, Tightening Torque 14 Lb-In.

- Input - No. 8-2 AWG, Tightening Torque 40 Lb-In. Output - No. 14-6 AWG, Tightening Torque 17.5 Lb-In. Auxilliary terminal (1 hole) 8-4 AWG, Tightening Torque 14 Lb-In.

Marking: Company name and catalog designation (catalog designation may appear on shipping carton).

Last Updated on 2008-07-31

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2009 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2009 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

